

**AMENDMENT TO THE NORTH CENTRAL TEXAS PUBLIC WORKS CONSTRUCTION
STANDARDS, AMENDED FIFTH EDITION, AUGUST 2023**

DIVISION 500 UNDERGROUND CONSTRUCTION & APPURTENANCES

ITEM 501 UNDERGROUND CONDUIT MATERIALS

501.7 Ductile-Iron Pressure Pipe and Fittings

501.7.3 Coating and Lining

The second sentence is amended to read:

“The cement mortar lining shall be in accordance with the latest revision of ANSI /
AWWA C104 / A21.4 American National Standard for Cement-Mortar Lining for
Ductile-Iron Pipe and Fittings for Water.”