

**AMENDMENT TO THE NORTH CENTRAL TEXAS PUBLIC WORKS CONSTRUCTION
STANDARDS, AMENDED FIFTH EDITION, AUGUST 2023**

DIVISION 500 UNDERGROUND CONSTRUCTION & APPURTENANCES

ITEM 502 APPURTENANCES

502.10 Connections to Conduit for Service

502.10.3.2 Services and Bullheads

The second paragraph is amended to read:

“The end of each water service connection shall be marked with heavy gauge polyethylene, locatable/traceable tape, 6-inches in width with a thickness of 0.004-inches. The tape should be blue in color on which has been printed “Caution Buried Water Line Below” in continuous print. The tape should have a minimum tensile strength of 1700-psi lengthwise and 1200-psi crosswise.”

502.10.4 Wastewater Conduit Connections

The second paragraph is amended to read:

“The end of each wastewater service connection shall be marked with heavy gauge polyethylene, locatable/traceable tape, 6-inches in width with a thickness of 0.004-inches unless a cleanout is present. The tape should be green in color on which has been printed “Caution Buried Wastewater Line Below” in continuous print. The tape should have a minimum tensile strength of 1700-psi lengthwise and 1200-psi crosswise.”