



North Central Texas Council of Governments

SUMMARY

Public Works Standard Drawings Subcommittee

Monday, November 16, 2020

10:00 AM – 11:30 AM

Microsoft Teams

[https://teams.microsoft.com/l/meetup-](https://teams.microsoft.com/l/meetup-join/19%3ameeting_MTc0NzRiZTkzMzQzYi00MTg2LWFIZmQtNTgxOTc3MDNIMDg0%40thread.v2/0?context=%7b%22id%22%3a%222f5e7ebc-22b0-4fbe-934c-aabddb4e29b1%22%2c%22oid%22%3a%222370af9a-6a25-4148-ae37-eafdba62b654%22%7d)

[join/19%3ameeting_MTc0NzRiZTkzMzQzYi00MTg2LWFIZmQtNTgxOTc3MDNIMDg0%40thread.v2/0?context=%7b%22id%22%3a%222f5e7ebc-22b0-4fbe-934c-aabddb4e29b1%22%2c%22oid%22%3a%222370af9a-6a25-4148-ae37-eafdba62b654%22%7d](https://teams.microsoft.com/l/meetup-join/19%3ameeting_MTc0NzRiZTkzMzQzYi00MTg2LWFIZmQtNTgxOTc3MDNIMDg0%40thread.v2/0?context=%7b%22id%22%3a%222f5e7ebc-22b0-4fbe-934c-aabddb4e29b1%22%2c%22oid%22%3a%222370af9a-6a25-4148-ae37-eafdba62b654%22%7d)

1. **Welcome and Introductions.**
2. **Meeting Summary.** The subcommittee can provide feedback on the October 19th meeting summary.

Olivia will follow up with more Subcommittee members to see if there are any changes or edits that need to be made.

3. **Review Drawings 6020 and 6030.** The subcommittee will review drawings 6020 and 6030 that Half Associates worked on.

6020

- No step ladder allowed, confined space entry regulations
- “construction joints key” arrow pointed at the floor
- 6020B “the” misspelled

6030

- Trim line at base to stop at the interior of the wall, it should not extend to the exterior wall – not indicating a keyway at the base of the inlet
- There needs to be consistency of callout “w” on 6020 and 6030
- Add note to table, “Drops greater than 10’ need to be structurally engineered.”

4. **Division 4000 Drawings Review.** The subcommittee will continue reviewing Division 4000 Drawings.

4110

- The angle of the corporation cock should be no more than 45 degrees and no less than 90 degrees

4120

- Bring service up and add meter setters

4130

- Add note, “Meter setters may be required by owner or water provider”

4140

616 Six Flags Drive, Centerpoint Two
P.O. Box 5888, Arlington, Texas 76005-5888
(817) 640-3300 FAX: 817-608-2372
www.nctcog.org

- Add note, “Meter setters may be required by owner”
- 4200**
- Show water going over wastewater or change it to storm

The group discussed removing 4140 and adding 1 ½-2” lines to 4130. They also thought about removing 4150 and replacing it with a general detail with qualitative requirements. They want to wait for the survey results of who is using these details before making changes to 4130-4190.

5. **Next Steps.** Subcommittee will outline next steps to be taken by NCTCOG staff and the group as a whole before the next meeting.

Olivia will send out a survey to Regional Public Works members asking 1) if anyone is using 4130-4190B in their system 2) if they're using NCTCOG Standard Details for it and 3) would they want the details updated?

6. **Next Meeting.** The Standard Drawings Subcommittee next meeting is Monday, December 14, 2020 through Teams, https://teams.microsoft.com/l/meetup-join/19%3ameeting_ZjcxNTE2ZTMtMTVjYS00OTVhLWE2YjEtZTcwYWUyMGZhMGZh%40thread.v2/0?context=%7b%22Tid%22%3a%222f5e7ebc-22b0-4fbe-934c-aabddb4e29b1%22%2c%22Oid%22%3a%222370af9a-6a25-4148-ae37-eafdba62b654%22%7d.

7. **Adjournment.**

If you plan to attend this public meeting and you have a disability that requires special arrangements at the meeting, please contact Olivia Kale by email at okale@nctcog.org, 72 hours in advance of the meeting. Reasonable accommodations will be made to assist your needs.